



City of Tacoma

## Questions and Answers

### Links to Opportunity Streetscape – Bid Package 5 RFB Specification No. PW23-0160F

All interested parties had the opportunity to submit questions in writing by email to Carly Fowler, Senior Buyer by June 17, 2024. The answers to the questions received are provided below and posted to the City's website at [www.TacomaPurchasing.org](http://www.TacomaPurchasing.org). Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click [Questions and Answers](#) for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

**Question 1:** I was wondering if you could help inform me on where I could find the specs on the Steel poles you plan on using for this project?

Answer 1: Depending upon which poles are being requested, refer to Special Provisions:

Section 8-20 ILLUMINATION, TRAFFIC SIGNAL SYSTEMS, INTELLIGENT TRANSPORTATION SYSTEMS, AND ELECTRICAL

Section 8-35 VERTICAL MARKER COLUMNS

9-29.6 Light and Signal Standards

STANDARD PLAN J-28.70-04

**Question 2:** I have a question concerning the PW 23-160F Project . Links to Opportunity Streetscapes ..

**B/I #R-74 CEM. CONC. COLORED 4860 SF**

**What is the Color of the concrete ?? What is the Measurement And Payment for that Items ..**

Answer 2: See Special Provisions Section 8-39

Section 8-39.2 **Materials:**

Concrete color shall be Euclid Chemical, Increte Color-Crete Charcoal 14 (CC150)

**8-39.13 Measurement**

Cement colored concrete shall be measured by the square foot of finished surface.

**8-39.14 Payment**

Payment will be made for the following Bid items when included in the Proposal:

“Cement Colored Concrete”, per square feet.