

CITY OF TACOMA
REQUEST FOR QUOTATION
GENERAL TERMS AND CONDITIONS

This Request for Quotation is governed by City of Tacoma Standard Terms and Conditions linked below.

<http://cms.cityoftacoma.org/purchasing/StandardTermsandConditions.pdf>



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053053

Return Bids By 11:00 AM, 12/27/2024
to: sendbid@cityoftacoma.org

Merry Elizabeth Mitchell
 Water Purchasing
 ABN 4th Floor NE
 3628 South 35th Street
 Tacoma WA 98409

Material will ship to:

Water Warehouse
 3506 S 35th St
 Tacoma WA 98409

RFQ Information	
Collective Bid #	TW24-0309N
Bid Issue Date	12/17/2024
Vendor Number	109226 WEB VENDOR FOR RFQ
Vendor Information (vendor to complete)	
Firm Name:	
Address:	
City/State/Zip	/ /
Phone/Fax	/
E-Mail	
Contact Name	
Payment Terms	%, days (e.g. 2% 10,N30)
Tacoma Bus. Lic. #	
Taxpayer ID #	
SIGNATURE OF PERSON AUTHORIZED TO SIGN THIS BID	
x _____	DATE: ___ / ___ / _____
NAME : _____	
TITLE : _____	

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	<p>The City of Tacoma is soliciting bids for purchase of Hardware Non-Electrical (Stock)</p> <p>Submittals may be e-mailed to sendbid@cityoftacoma.org for this solicitation.</p> <p>Please include the Collective Bid Number, TW24-0309N, in the subject line of your e-mail.</p> <p>Bids are subject to the submittal deadline noted in the bid solicitation document. The time of e-mail receipt will be considered as the time of submittal. The City accepts no responsibility for transmission errors.</p> <p>We are unable to verify receipt of submittals due to the large volume of submittals received.</p> <p>Extend net price and provide net total value. All bid pricing shall be FOB Destination, freight prepaid and included in the unit price.</p> <p>Materials must be new and unused. No substitutes are allowed. Substitute items will be returned at vendor's expense.</p>					



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	<p>Delivery date will default to two weeks ARO if vendor fails to provide.</p> <p>Please Circle or underline the part number and manufacturer quoted or bid may be considered non-responsive.</p> <p>If applicable, you must select from the approved manufacturer(s) listed. Substitutions will not be approved at the time of the bid awarding. If you have a material that you would like to have added, it must be submitted for review and approved by the City of Tacoma's Material Committee before the bid issue date listed on this request for quotation. For more information regarding this process, please contact: Merry Mitchell, mmitchell@cityoftacoma.org</p> <p>Responses MUST BE SUBMITTED on the provided City of Tacoma bid solicitation form. Vendor signature is MANDATORY.</p> <p>Bid results will be posted at: http://www.cityoftacoma.org/government/city_departments/finance/procurement_and_payables_division/purchasing/bid_results/</p> <p>Note: You must register at this website as a bid holder for each solicitation of interest in order to receive notification regarding amendments or other updates to the original bid solicitation documents.</p> <p>City Contact: Merry Mitchell, mmitchell@cityoftacoma.org</p>					



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be
 plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
10	<p>32192</p> <p>YOKE,2IN X 18IN X 17IN,METER YOKE, METER, 2 INCH X 18 INCH X 17 INCH, 2 INCH COPPER METER SETTER WITH FEMALE IRON PIPE, HORIZONTAL INLET AND OUTLET, FULL PORT ANGLE METER BALL VALVE INLET AND OUTLET AT THE METER, HIGH BY-PASS. MINIMUM 1 IN COPPER TUBE WITH LOCKING BALL VALVE. CENTER LINE OF HIGH BY-PASS TO BE OFF SET 6-1/2 TO 7-1/2 INCHES FROM THE CENTER LINE OF THE INLET AND OUTLET RISERS, AND 5 TO 8-1/2 INCHES BELOW THE CENTER LINE OF METER FLANGES. ALL BALL VALVES MUST HAVE PAD LOCK WINGS. ALL MATERIALS USED IN THE CONSTRUCTION OF THE SETTERS SHALL CONFORM TO THE APPLICABLE SECTIONS OF THE LATEST REVISION OF AWWA STANDARD C-800.</p> <p>BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.</p> <p>*NOT ACCEPTABLE MUELLER, FORD*</p> <p>APPROVED A.Y. MCDONALD 720R718WWFF775</p> <p>Material # Manf Part# Manufacturer Name 10006872 720R718JJFF775 A.Y. MCDONALD</p>		30	EA		



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
20	30804	<p>ADAPTER,8IN X 24IN,FLNG X FLNG,DI ADAPTER, FLANGE X FLANGE, 8INCH INSIDE DIAMETER X 24 INCH LAYING LENGTH, DUCTILE IRON, MORTAR LINED. CAST CLASS 52 OR FABRICATED USING SPECIAL CLASS 53 DI PIPE WITH THREADED (SOLID BACK) DUCTILE IRON FLANGES(CLASS 125). MUST COMPLY WITH THE LATEST REVISIONS OF AWWA STANDARDS; C-104, C-110, C-115, C-150, C-151 AND C-153.</p>		6	EA		
30	31468	<p>PLUG,8IN,PIPE,DI,MECHANICAL JOINT PLUG, PIPE, 8 INCH DUCTILE IRON, MECHANICAL JOINT, 6 HOLES, SOLID, NOT TAPPED, WITHOUT BOLTS, GASKETS OR GLANDS. FITTING TO COMPLY WITH ANSI/AWWA C104 AND ANSI/AWWA C153.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST BE MANUFACTURED WITHIN TWO YEARS OF THE DATE OF THE PURCHASE ORDER UNLESS PRIOR APPROVAL IS OBTAINED FROM TACOMA WATER.</p>		2	EA		
40	31977	<p>STOP,5/8X3/4,WATER,YOKE,LOCK ON/OFF STOP, WATER, YOKE, 5/8" X 3/4", LOCK ON/OFF</p> <p>BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.</p> <p>*NOT ACCEPTABLE MUELLER*</p> <p>APPROVED: FORD NO. BA13-232WW 5/8" AY MCDONALD NO. 74644 BWW 3/4".</p>		400	EA		



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be
 plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
50	32129	<p>NIPPLE,2IN X CLOSE,RED BRASS NIPPLE,RED BRASS, 2 INCH X CLOSE</p> <p>MUST MEET ASTM B43 FOR SEAMLESS RED BRASS PIPE AND NSF 372 FOR LEAD CONTENT.</p>		12	EA		
60	35527	<p>VALVE,8IN,GATE,FLNG X FLNG GATE, VALVE, FLANGE X FLANGE, 8", CAST IRON, WITH 2" OPERATING NUT WHICH OPERATES LEFT TO OPEN (COUNTER CLOCK WISE), NON RISING STEM, UL LISTED AND FM APPROVED VALVES SHALL CONFORM TO THE LATEST REVISION OF AWWA C515 AND AWWA C550. FLANGED ENDS SHALL CONFORM TO C110/A21.10, (ANSI B16.1, CLASS 125)</p> <p>Material provided under this specification must be manufactured within two years of the date of the purchase order unless prior approval is obtained from Tacoma Water.</p>		5	EA		
	Material #	Manf Part#	Manufacturer Name				
	10004325	STYLE 2360	MUELLER				
	10004324	METROSEAL 250	US PIPE				
	10004323	STYLE 4067	M&H				
	10004322	MODEL RWGV-96	KENNEDY				
	10004321	RS	CLOW VALVE CO				
	10009940	SERIES 2500	AMERICAN FLOW CONTROL				
	10009025	FLOW MASTER	EAST JORDAN IRON WORKS				
	10006861	25-200-40	AVK International				



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be
 plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
70	76281	<p>TEE, 12IN X 8IN, TAPPING, SS TEE, TAPPING, 12IN X 8IN, STAINLESS STEEL, RANGE 13.16-13.56 DUCTILE IRON FLANGED OUTLET.</p> <p>*****</p> <p>APPROVED</p> <p>ROMAC INDUSTRIES, INC</p> <p>SSTIII- 13.56 X 8" D.I FLG</p> <p>NO EXCEPTIONS</p> <p>*****</p> <p>Material # Manf Part# Manufacturer Name 76281 SSTIII-13.56 X 8" D.I FLG ROMAC</p>		2	EA		
80	32005	<p>COUPLING, 2IN, CAST BRONZE COUPLING, CAST BRONZE, 2 INCH.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"</p> <p>*NOT ACCEPTABLE MUELLER*</p>		30	EA		



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053053

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
90	31152	<p>GLAND PACK,24IN,MJ,DI 24" GLAND PACKAGE. MECHANICAL JOINT, DUCTILE IRON, PER THE LATEST REVISION OF ASTM A536. INDIVIDUAL PACKAGES (BOXED) WILL INCLUDE A "SBR" MJ GASKET AND 16 EACH 3/4" X 5" CORTEN T-BOLTS AND A MJ GLAND.</p> <p>APPROVED:</p> <p>*****</p> <p>NOT APPROVED: UNION FOUNDRY, STAR PIPE PRODUCT</p> <p>*****</p>		6	EA		
100	75282	<p>COUPLING,1-1/4IN x 3/4IN,REDUCING,BRASS COUPLING, PIPE, REDUCING, BRASS, 1-1/4 INCH X 3/4 INCH.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT</p>		10	EA		
110	31811	<p>VALVE,3/4IN IPT,DOUBLE CHECK VALVE,DOUBLE CHECK,3/4 IPT</p> <p>BRASS COMPONENTS THAT CONTACT WATER MUST MEET NSF/ANSI 372.</p> <p>*Note this may or may not be installed for potable water use, use Lead free in case it is.</p> <p>APPROVED: FEBCO SERIES LF850 DOUBLE CHECK VALVE WILKINS MODEL 350XL</p>		2	EA		

Net Value	\$
Plus Tax at	
_____ %	\$
Total Amount	\$