



**City of Tacoma
Tacoma Water
Cornell 30 HP Pump and Motor for Tacoma Pump Station
Specification No. TW24-0212N**

QUESTIONS and ANSWERS

All interested parties had the opportunity to submit questions in writing by email to Becky Lewis by September 6, 2024. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to *Current Contracting Opportunities / Supplies*, and then click *Questions and Answers* for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: Technical Provisions Item 3: FACTORY PUMP TESTS – If we are only supplying and delivering the pump and motor is this scope still to be included?

Answer 1: Yes, Factory Pump Tests are required. This ensures we get the performance curve we want.