



City of Tacoma

## Tacoma Water

**ADDENDUM NO. 1**

**DATE:** July 1, 2024

**REVISIONS TO:**

**Request for Proposals Specification No. TW24-0129N  
Indian Hill 3.5MG Reservoir Re-Roof**

**NOTICE TO ALL PROPOSERS:**

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

**REVISIONS TO THE SUBMITTAL DEADLINE:**

The submittal deadline remains the same.

**REVISIONS TO THE SPECIAL PROVISIONS:**

Section 1 – Minimum Qualifications

Replace the existing statement with the following text, 'Only bids from contractors with satisfactory experience and a successful performance record will be considered in awarding the contract. The Contractor must have experience in the construction and rehabilitation of large concrete structures and the application of coatings on large concrete structures. Bidders must complete the Record of Prior Contracts Form included in this Specification and submit it with their bid proposal. Bid submittals not demonstrating adequate experience may be rejected. The City shall be the sole judge of the bidder's ability to meet the requirements of this paragraph'.

Section 13 – Prevailing Wage Information

Replace the statement that 'The project site is located in Unincorporated Pierce County at the intersection of Aqueduct Dr E and 99<sup>th</sup> St E', with the statement that 'The project site is located in Federal Way along Orca Drive NE'.

Section 41 – Planning the Work

Delete Paragraph A. The Contractor shall verify the location and elevation of all other utilities, including the existing water main to be worked on, sufficiently in advance of approaching them with the water main connections construction so that corrections in vertical and/or horizontal alignment may be accomplished if necessary.

Rename Paragraph B as Paragraph A.



City of Tacoma

Replace Paragraph C to read: The Contractor shall give Tacoma Water two (2) weeks in advance written notice to schedule shutdown of the reservoir.

Rename Paragraph C as Paragraph B.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the Signature Page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Proposals Specification No. TW24-0129N Addendum No. 1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Michel Peloquin, Civil Engineer, PE, Tacoma Water