



City of Tacoma

## Questions and Answers

### 2025 GRW CULVERT IMPROVEMENTS RFB Specification No. TW25-0009N

All interested parties had the opportunity to submit questions in writing by email to Brandon Snow, Senior Buyer by date questions were due. The answers to the questions received are provided below and posted to the City's website at [www.TacomaPurchasing.org](http://www.TacomaPurchasing.org). Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click *Questions and Answers* for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

- 1. Question: In the bid package it says the value is \$88,000.00. Is this a mistake? Based on the scope of work, the project will be way more than that and I just want to confirm the value.**

Answer: Yes, \$88,000 is the engineers correct estimate. This is just an estimate, please bid to ensure you cover all your costs.

- 2. Question: There are power lines above the culvert installation at the 1.00, what is the safe working distance to the power lines?**

Answer: PSE recommends that equipment stay 15 to 20 feet away from the lines. The lines are measured at 65 feet above the roadway.

- 3. Question: Do you have to attend the pre-bid meeting to bid the project?**

Answer: No, you do not have to attend the pre-bid meeting to bid the project.